

January 2007

QUARTERLY INSPECTION

CITY HALL

NOTHING TO REPORT

CITY SHOP

GENERAL CLEAN UP

SEWER PLANT

LIGHTS IN OLD LAB - need repair

APARTMENT

NOTHING TO REPORT

COMMUNITY CENTER

LIGHTS

COMMONS PARK

NOTHING TO REPORT

LIGHT COVER IN HALLWAY

TILE FLOOR STARTING TO BREAK

FENCE AROUND BASEMENT NEEDS TO BE REPLACED

EXIT SIGNS NEED NEW BULBS

PERKINS PARK

NOTHING TO REPORT

Add - sagging roof
Gutters - have inspector check
FIRE HALL

TERRY PARK

NOTHING TO REPORT

CONCERNS ABOUT CONSTRUCTION

OTHER

QUARTERLY INSPECTION

CITY HALL

Clear out area by bathroom

CITY SHOP

Shop Clean in General
Some Tripping Hazards
Extinguishers Checked

SEWER PLANT

Light in Old Lab
Extinguishers OK

APARTMENT

N/A

COMMUNITY CENTER

COMMONS PARK

OK

PERKINS PARK

INSTALL SMALL RETAINING WALL
✓ REMOVE 4x4 POST THAT HAVE BROKEN
TIGHTEN PARTS ON PLAY STRUCTURE
REMOVE SWING SET
✓ FIX CHAINLINK FENCE
TERRY PARK

FIRE HALL

OK

OTHER

Alum Bldg - OK
SODA Bldg - OK

QUARTERLY INSPECTION - MAY 2006

CITY HALL

~~OK~~

PHONE LINE ON
SKIP'S PHONE

CITY SHOP

OK

SEWER PLANT

OK

APARTMENT

N/A

COMMUNITY CENTER

OK

PARKS

PERKINS - WELLHOUSE NEEDS
GENERAL CLEANING. SOME
LOOSE BOLTS ON PLAY EQUIPMENT

TERRY - OK

FIRE HALL

OK

MISC

SODA BUILDING - GUARD ON SODA PUMP
LIFT STATION, OK

Inspected 2/28/06

QUARTERLY INSPECTION

J. Anderson

J. Biglin

CITY SHOP

CITY HALL

Rep Skips phone line tight up against cabinet
Replace yellow tape at E-Box in Council Chambers

Clean steps
General Clean up
Inspected ABC Extinguishers
checked Electrical Area - OK

SEWER PLANT

Inspected ABC Extinguishers (2)
Clean as always

APARTMENT

COMMUNITY CENTER

Missing one light cover
Extinguishers OK

Replace light cover in S. Hallway
first aid kit OK

PARKS

Perkins OK
Commons OK
Terry OK

FIRE HALL

Have shore power to E-102 finished

MISC

4th St. LS. OK ✓ Extinguishers
Wilson St. LS OK ✓ Extinguishers

3/28/05

QUARTERLY INSPECTION

CITY HALL

Pipe stru exposed in Council Chambers

Electrical outlet in Admon needs to be covered (fax)

Service Fire Extinguisher

CITY SHOP

Replace guard on grinder - DONE

Chain propane tanks

Burn barrel was removed after last inspection

SEWER PLANT

Fix EXIT Light in Lab

Service Fire extinguisher

CITY RENTAL

Unable to check

COMMUNITY CENTER

Storage room needs to be cleaned

Remove all items from front of circuit panel

Fix Exit Light

PARKS

Removed Gazebo from Perkins Park - fill in holes

Perkins - replace child's swing

Terry - okay

Commons - okay

FIRE HALL

Lines were painted on floor

Tape around Electrical box

Service fire extinguisher

MISC

Clean up Alum bldg

Conducted by J. Rhodes
T. Lucich